

5

# Inspection Report

Name of the building :- West End High School  
G + 1 approved by Jhargram Municipality

Address : Bandarbhola Ekalabya Sarani  
P.O & Dist : Jhargram Ward No. 11

Nature of the building : Educational

The persons present at the time of Inspection and signature

*[Signature]*  
P. BARIK  
Secretary  
Jhargram Municipality

Surrounding Space

North - Pucca road (Jamboni road)

East - Barun Chatterjee

West - P. Barik

South - 20' Wide Mouram Road

Abutting Road

9 mts.

Total covered area 1278 sq.mts as stated in the plan.

Fire safety point of view

Electrical meter-

Pump, Horse real,

Extinguishes, Detectors

Electric - own Transformer

D.G & 3 phase electrical line

Overhead Water Tank 8000 lts and Ground level reservoir (Provision)

Remarks.....

The inspection made by the O/C fire bridged Jhargram. The Executive Engineer, P.W.Dte Electrical on 02/07/2020. On the basis of inspection as desired from the authority of West End High School, Bandarbhola, Jhargram declared fit far run.

Countersigned

*[Signature]*  
02/07/2020  
Executive Engineer,  
Jhargram Electrical Division  
P.W. Dte.

*[Signature]*  
2/7/2020  
PULAK SHARMA  
OFFICER IN CHARGE  
JHARGRAM FIRE STATION  
WB F & ES