

GENERAL WATER TESTING LABORATORY, JHARGRAM



Paschim Medinipur, Zilla Parishad & PHED

Sponsored By (Govt. of West Bengal)

Monitored by :- Jhargram Mahakuma Janasiksha Prasar Samity

Raghunathpur :: Jhargram :: (03221) 255329

Source Type :- W/T.W./D.T./Other (Specify) *Drinking water distribution point*

Collected By :-
Biplab Ghit

Collected From :-
*West End High School
Bandarbhata, Jhargram*

Collected on :- *07/07/2020*

Test Completed on :- *09/07/2020*

Physical Appearance :-

Clear / Turbid (Turbidity.....) *1.10*

Smel :- *NO smel*

Microbial Test Findings :-

Sl. No.	Test Performed	Unit	Result	Normal Range
1	Total Coliform	MPN/100ml	NIL	00
2	Feacal Coliform	MPN/100ml	NIL	00

Chemical Test Findings :-

Sl. No.	Test Performed	Unit	Result	AL - PL
1	pH	NULL	<i>6.45</i>	6.5 - 8.5
2	Residual Chlorine	mg / Ltr	NIL	0.2 - 2.00
3	Total Iron As Fe	mg / Ltr	<i>0.06</i>	0.3
4	Manganese	mg / Ltr	NIL	0.1 - 0.3
5	Total Hardness	mg / Ltr	<i>86</i>	200 - 600

Remarks :-

The Sample Water is Chemically Safe / ~~Unsafe~~ :-

The Sample Water is Bacteriologically Safe / ~~Unsafe~~ :-

Suggestion :- 1.....

2.....

[Signature]
Secretary
Jhargram Mahakuma
Janasiksha Prasar Samity

[Signature]
Chemist
Water Testing Laboratory
Jhargram

[Signature]
Bacteriologist
Water Testing Laboratory
Jhargram